DeviceNET®

Ranges: 0-600 to 0-1700 inches

Industrial Grade

Specification Summary:

GENERAL


Full Stroke Range Options—on this datasheet.	0-600 to 0-1700 inches
Electrical Signal Interface	CANbus ISO 11898
Protocol	DeviceNET Version 2.0
Accuracy	± 0.10% full stroke
Repeatability	± 0.02% full stroke
	± 0.003% full stroke
Measuring Cable	nylon-coated stainless steel
	powder-painted aluminum or stainless steel
Sensor	plastic-hybrid precision potentiometer
Potentiometer Cycle Life250	0,000, min. – before signal degradation can occur
Maximum Retraction Acceleration	see ordering information
	see ordering information
Weight, Aluminum (Stainless Steel) Enclosu	re


ELECTRICAL

Input Voltage	bus powered
Input Current	
Address Setting/Node ID	063 set via DIP switches -default setting: 63
Baud Rate	125K, 250K or 500K set via DIP switches
EDS File	. available @ http://www.celeso.com/download

ENVIRONMENTAL

Enclosure	NEMA 4/4X/6, IP 67
Operating Temperature	40° to 200°F (-40° to 90°C)
Vibration	up to 10 G's to 2000 Hz maximum





	600 in.	800 in.	1000 in.	1200 in.	1500 in.	1700 in.
A	1.76 [44,7]	1.58 [40,1]	1.98 [50,2]	1.49 [37,8]	1.86 [47,2]	2.11 [53,6]
B	4.52 ±0.15 [114,8 ±4,0]			46 ±0.15 [138,7 ±4,		
•	10.40 ±0.08 [264,2 ±2,0]		11	.34 ±0.08 [288,0 ±2	,0]	
D	12.15 [308,6] max.			13.09 [332,5] max.		

full stroke range

DIMENSIONS ARE IN INCHES [MM] tolerances are 0.03 IN. [0.5 MM] unless otherwise noted.

* tolerance = +.005 -.001 [+.13 -.03] ** tolerance = +.005 -.005 [+.13 -.13]


<Extended Range> PT9D




The PT9DN communicates via DeviceNET protocol with programmable controllers in factories and harsh environments requiring linear position measurements in ranges up to 1700".

As a member of Celesco's innovative family of NEMA 4 rated cable-extension transducers, the PT9DN installs in minutes by simply mounting it's body to a fixed surface and attaching it's cable to the movable object. Perfect parallel alignment not required.

Output Signal





Data Field Full Stroke Not Used Range* Not Used Count* B_4 B_7 **B**₆ **B**₅ B_3 B_2 B_1 B_0 = LSB current measurement byte **B₂** = LSB full stroke range byte **B**₁ = MSB current measurement byte B3 = MSB full stroke range byte

*Current Measurement Count

The Current Measurement Count (CMC) is the output data that indicates the present position of the measuring cable.

The CMC is a 16-bit value that occupies the first two bytes (B₀ and B₁) of the data field. B₀ is the LSB (least significant byte) and B₁ is the MSB (most significant byte).

The CMC starts at 0000H with the measuring cable fully retracted and continues upward to the end of the stroke range stopping at FFFFH. This holds true for all ranges.

**Full Stroke Range

The Full Stroke Range (FSR) is a 16-bit value in the data field that expresses the full range of the sensor in inches. This value can be used to convert the actual count to units of measurement should the application require it.

The full stroke measurement range occupies the second two bytes (B2 and B3) of the data field.

B₂ is the LSB (least significant byte) and B₃ is the MSB (most significant byte).

This value is expressed in inches.

Example:

Hex Value	Decimal Equivalent	Full Stroke Range
001F	30	30 inches

Converting CMC to Inches

If required, the CMC can easily be converted to a linear measurement expressed in inches instead of just counts.

This is accomplished by first dividing the CMC by 65,535 (total counts over the range) and then multiplying that value by the FSR:

Example:

If the full stroke range is 30 inches and the current position is OFF2 Hex (4082 Decimal) then,

$$\left(\frac{4082}{65,535}\right)$$
 X 30.00 inches = 1.87 inches

Address Setting (Node ID), Baud Rate and Bus Termination Settings

Address Setting (Node ID)

The Address Setting (Node ID) is set via 6 switches located on the 8-pole DIP switch found on the DeviceNET controller board located inside the transducer.

The DIP switch settings are binary starting with switch number $1 (= 2^0)$ and ending with switch number $6 (= 2^5)$.

DIP-1 (2 ⁰)	DIP-2 (2 ¹)	DIP-3 (2 ²)	DIP-4 (2 ³)	DIP-5 (2 ⁴)	DIP-6 (2 ⁵)	address (decimal)			
0	0	0	0	0	0	0			
1	0	0	0	0	0	1			
0	1	0	0	0	0	2			
•••	•••	•••	•••	•••	•••	***			
1	1	1	1	1	1	63			
1 2 3 4	↑ = "0" 12343673 ↓ = "1"								

Baud Rate

The transmission baud rate may be either factory preset at the time of order or set manually at the time of installation.


The baud rate can be set using switches 7 & 8 on the 8-pole DIP switch found on the DeviceNET controller board located inside the transducer.

DIP-7	DIP-8	baud rate
0	0	125k
1	0	250k
0	1	500k
1	1	125k


Bus Termination


The setting of the internal bus termination resistor may be specified upon order or manually changed by the end user at the time of installation.

The bus termination resistor is activated setting switches 1 & 2 on the 2-pole DIP switch (located on the internal DeviceNET controller board) to the "ON" position.



DeviceNET Controller Board and DIP Switch Location





PT9DN Extended Range • Cable-Extension Transducer: DeviceNET®

Ordering Information:

Model Number:



Sample Model Number:

PT9DN - 1200 - AL - FR - 500 - TR - SC5

ange.
enclosure
cable exit:
baud rate:
terminating resistor:
electrical connection:

front (horizontal) 500 k bits/sec.

5-meter cordset with straight plug

Full Stroke Range:

•											
R order code:	600		800		1000		1200		1500		1700
full stroke range, min:	600 in.	:	800 in.	:	1000 in.	:	1200 in.	:	1500 in.	:	1700 in.
cable tension (±35%):	27 oz.	:	24 oz.	:	20 oz.	:	19 oz.	:	18 oz.	:	17 oz.
	.034-in. dia.	:	.019-in. dia.	:	.019-in. dia.	:	.019-in. dia.	:	.014-in. dia.	:	.014-in. dia.
measuring cable:	nylon-coated	:	nylon-coated								
-	stainless	:	stainless								

Enclosure Material:

A order code:	AL	SS
enclosure material:	powder-painted aluminum	303 stainless steel
max. acceleration:	1G	.33G
max. velocity:	60 inches/sec.	20 inches/sec.

Cable Exit:

B order code:	FR	UP	ВК	DN
	front	top	back	down

Baud Rate:

@ order code:	125	250	500
	125 kbaud	250 kbaud	500 kbaud

Terminating Resistor:

note: order code: TR NR

terminating resistor

no terminating resistor

PT9DN Extended Range • Cable-Extension Transducer: DeviceNET®

Ordering Information:

Electrical Connection:

